

Test Report No./ Sample Id : DLL-62(B)
Issue Date : 18-07-2023
Issued To : HOLY CHILD SCHOOL
Sample Description : SAMPLE BOTTLE PROPERLY SEALED
Sample Location : DUBLAPADUNG, NAMONIGAON
BLOCK : RANGAPARA
Sample Type : D/T/W(R)
Sample Quantity : 1000 ml
Sample Collected on Dated : 14-07-2023
Sample Received on Dated : 14-07-2023
Sample Collected By : MRINAL BASUMATARY
Date of Analysis Started: 14-07-23 Date of Analysis Completed: 17-07-2023

Test Report

Sr. No.	Bacteriological Parameter	Protocol Used	Results	IS: 10500:2012 (Second Revision)		Unit
				Desirable limit	Max. Permissible limit (in absence better alternate source)	
1	Coliform	MF Technic	78	No relaxation	No relaxation	CFU/100 ml
2	E-Coli	MF Technic	NOT DETECTED	No relaxation	No relaxation	CFU/100 ml
3	Residual Chlorine	Iodometric Method [APHA 4500-Cl B]	0	0.2	1	Mg/l

- Notes:**
- The results given above are related to the sample as received and tested in this laboratory. Reliability of sample lies with the sender.
 - The test report cannot be regenerated/re-produced in whole or in part without written permission of Laboratory.
 - The test report cannot be used for any publicity or any legal purpose.
 - The test samples meant for chemical analysis will be disposed of after 15 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Sample analyzed by: Baishali Rajbongshi,


Quality Manager
DLL Sonitpur, Tezpur Division No.1
District Level Laboratory
Sonitpur


Microbiologist
DLL Sonitpur, Tezpur Division No.1
District Level Laboratory
Sonitpur

LABORATORY NAME: DISTRICT LEVEL LABORATORY (PHED), SONITPUR
Address: OFFICE OF THE EXECUTIVE ENGINEER (PHE) TEZPUR DIVISION NO.1
RUBBER BAGAN, TEZPUR

Email ID: dll.6tezipur@gmail.com

ULR NO: TC-10522 23 000002625 F

Test Report No./ Sample Id : DLL-62
 Issue Date : 18-07-2023
 Issued To : HOLY CHILD SCHOOL
 Sample Description : SAMPLE BOTTLE PROPERLY SEALED
 Sample Location : DUBLAPADUNG, NAMONIGAON
 BLOCK : RANGAPARA
 Sample Type : D/T/W(R)
 Sample Quantity : 1000 ml
 Sample Collected on Dated : 14-07-2023
 Sample Received on Dated : 14-07-2023
 Sample Collected By : MRINAL BASUMATARY
 Date of Analysis Completed: 17-07-2023
 Date of Analysis Started: 14-07-23

Test Report

Sr. No.	Parameter	Protocol Used	Results	IS: 10500:2012(Second Revision)		Unit
				Desirable limit	Max. Permissible limit (in absence better alternate source)	
1	Taste	IS: 3025 (part 8)	AGGREGABLE	Aggreable	Aggreable	
2	Turbidity	IS: 3025 (Part 10)	16.6	1	5	NTU
3	pH	IS: 3025 (Part 11)	6.78 @26°C	6.5 – 8.5 @25±2°C	No relaxation	pH unit
4	TDS	IS: 3025 (Part 16)	48	500	2000	mg/L
5	Chloride	IS : 3025 (Part 32)	7.09	250	1000	mg/L
6	Total Alkalinity	IS: 3025 (Part 23)	100	200	600	mg/L
7	Total Hardness	IS: 3025 (Part 21)	56	200	600	mg/L
8	Calcium (as Ca)	IS: 3025 (Part 40)	17.61	75	200	mg/L
9	Magnesium	APHA (23rd ed) 3500 Mg B	2.92	30	100	mg/L
10	Total Iron	APHA 3500 (23rd Ed) Fe B	2.44	0.3	No relaxation	mg/L
11	Arsenic	IS: 3025 (Part 37)	0	0.01	0.05	mg/L
12	Fluoride	APHA (23rd Ed) 4500 F F	0.57	1	1.5	mg/L
13	Nitrate	IS : 3025 (Part 34)	0.67	45	No relaxation	mg/L
14	Sulphate	IS 3025 (Part 24)	6.35	200	400	mg/L
15	Odour	IS 3025 (Part 5)	AGGREGABLE	Aggreable	Aggreable	
16	Colour	IS: 3025: Part 4	1	5	15	Hazen

Notes:

1. The results given above are related to the sample as received and tested in this laboratory. Reliability of sample lies with the sender.
2. The test report cannot be regenerated/re-produced in whole or in part without written permission of Laboratory.
3. The test report cannot be used for any publicity or any legal purpose.
4. The test samples meant for chemical analysis will be disposed of after 15 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Sample analyzed by: Pritam Modak

Baishali Rajbongshi
BAISHALI RAJBONGSHI
 Quality Manager

DLL Sonitpur Tezpur Division No.1

*****END OF TEST REPORT*****